



AUSTRALIAN RAIL TRACK CORPORATION LTD

*This document has been adopted by the ARTC with the permission of the NSW Government and will continue to apply under the authority of the ARTC General Manager Infrastructure, Strategy & Performance until further notice*

**Discipline**

**Engineering Standard – NSW**

**Category**

**Electrical**

**Title**

**Low Voltage Distribution and Installations  
Earthing References and Definitions**

**Reference Number**

**PDS 03 – (ARTC Standard: EP 12 00 00 02 SP)**

**Document Control**

<b>Status</b>	<b>Date</b>	<b>Prepared</b>	<b>Reviewed</b>	<b>Endorsed</b>	<b>Approved</b>
Issue 1 Revision 1	Mar 05	Standards and Systems	Signalling Standards Engineer	GM Infrastructure Strategy & Performance	Safety Committee
		Refer to Reference Number	T Moore	M Owens	Refer to minutes of meeting 24/01/05

## **Disclaimer**

Australian Rail Track Corporation has used its best endeavors to ensure that the content, layout and text of this document is accurate, complete and suitable for its stated purpose. It makes no warranties, express or implied, that compliance with the contents of this document shall be sufficient to ensure safe systems of work or operation. Australian Rail Track Corporation will not be liable to pay compensation in respect of the content or subsequent use of this document for any other purpose than its stated purpose or for any purpose other than that for which it was prepared except where it can be shown to have acted in bad faith or there has been willful default.

## **Document Approval**

The technical content of this document has been approved by the relevant ARTC engineering authority and has also been endorsed by the ARTC Safety Committee.

## **Document Supply and Control**

The Primary Version of this document is the electronic version that is available and accessible on the Australian Rail Track Corporation Internet and Intranet website.

It is the document user's sole responsibility to ensure that copies are checked for currency against the Primary Version prior to its use.

## **Copyright**

The information in this document is Copyright protected. Apart from the reproduction without alteration of this document for personal use, non-profit purposes or for any fair dealing as permitted under the Copyright Act 1968, no part of this document may be reproduced, altered, stored or transmitted by any person without the prior written consent of ARTC.

## **About This Standard**

This document lists the publications and drawings that are referenced in the documents contained in Volume 2 of this manual, or that can provide extra background information. The drawings are held in the RSA Plan Room in Transport House.

This document also provides a list of definitions of words that have a precise meaning in relation to the documents contained in Volume 2 of this manual.

## Document History

**Primary Source** – RIC Standard EP 12 00 00 02 SP Version 2.0

### List of Amendments –

ISSUE	DATE	CLAUSE	DESCRIPTION
1.1	11/03/2005	Disclaimer	Minor editorial change

## Contents

<b>1. References</b>	<b>7</b>
1.1. General Publications	7
1.2. Drawings	7
<b>2. Definitions used in this Volume</b>	<b>7</b>
2.1. 1500 V structure	7
2.2. Appreciable dc leakage current	8
2.3. Bonding conductor	8
2.4. Conductor	8
2.5. Consumer's mains	8
2.6. Consumers terminals	8
2.7. Distribution Substation	8
2.8. Earth grid (also known as Earth mat)	8
2.9. Earth potential rise	8
2.10. Earthing conductor	8
2.11. Earthing system	8
2.12. Electrified area	8
2.13. Electrode (also known as earth rod)	9
2.14. Electrolysis	9
2.15. High voltage	9
2.16. Installation main switchboard	9
2.17. Insulated	9
2.18. Local Electricity Distributor	9
2.19. Low voltage	9
2.20. Metalwork	9
2.21. Near 1500 V track	9
2.22. Point of attachment	10
2.23. Prospective touch voltage	10
2.24. ARTC consumer's terminals	10

2.25.	ARTC service mains .....	10
2.26.	ARTC supply .....	10
2.27.	Rail .....	10
2.28.	Railway corridor .....	10
2.29.	Remote earth .....	10
2.30.	Sectioning Hut .....	10
2.31.	Service equipment .....	10
2.32.	Service line .....	11
2.33.	Spark gap .....	11
2.34.	Step voltage .....	11
2.35.	Substation .....	11
2.36.	Supply main switchboard .....	11
2.37.	Switchboard .....	11
2.38.	System Substation .....	11
2.39.	Touch voltage .....	11
2.40.	Traction Substation .....	11
2.41.	Transfer voltage .....	12
2.42.	Transformer mains .....	12
2.43.	Voltage .....	12

## 1 References

### 1.1 General Publications

- AS-3000 - SAA Wiring Rules
- AS-3108 - Approval and test specification-particular requirements for isolating transformers and safety isolating transformers - 1990
- EC 5 - Guide to protective earthing - Electricity Council of N.S.W. - 1992
- UIC - 605-1 - International union of railways codes
- Cathodic protection of underground structures by W. K. Woodberry

### 1.2 Drawings

D 89147	Electrolysis isolating joint for underground water pipe.
A1 88496	Station low voltage electrical services general information
B 87137	Strathfield - MacDonaltdown S & C Relay Building Electrical Branch Power Room, Equipment Layout and Schematic Diagram
K 87124	Standard Platform Lighting Arrangement
C 87115	Earthing Systems. Arrangement of LV Installations in Contact with 1500V Structures.
B 82693	Train maintenance centres proposed low voltage earthing arrangements.
C 79930	HV outdoor equipment typical earthing arrangements.
D 77535	AC welding machines installation of earth leakage circuit breaker typical wiring diagrams.
C 74378	Modified earthing systems 415/240 V.

## 2 Definitions used in this Volume

### 2.1 1500 V structure

A 1500 V structure is a structure which has 1500 V equipment attached to it with insulators. This includes structures specifically designed for supporting overhead wiring and structures built for other purposes but also supporting overhead wiring, such as overbridges.

### 2.2 Appreciable dc leakage current

If 200 mA of dc current can be measured for a period of 2 hours during a test conducted over 24 hours, this structure or building is to be regarded as likely to pick up appreciable amounts of stray current.

### **2.3 Bonding conductor**

A bonding conductor is a conductor connecting two or more metal structures with 1500 V overhead wiring attached for the purpose of carrying traction fault currents during electrical disturbances. The bonding conductor shall have a minimum size of 70 mm<sup>2</sup> copper and shall be insulated to 0.6/1.0 kV.

### **2.4 Conductor**

A conductor is a wire, cable or other form of material suitable for carrying current.

### **2.5 Consumer's mains**

The consumer's mains the conductors between the point of attachment and the service equipment. They are determined in accordance with the local Electricity Distributor's Service and Installation Rules and from AS 3000.

### **2.6 Consumers terminals**

The consumers terminal is the point at which the Distributors system is connected to the consumer's installation.

### **2.7 Distribution Substation**

The distribution substation means all non-system substations containing high voltage electrical equipment (ie high voltage locations without circuit breakers).

### **2.8 Earth grid (also known as Earth mat)**

The earth grid or earth mat is a group of conducting elements, both vertical and horizontal, in electrical contact with the earth designed to disperse electrical fault currents into the earth and to control touch and step voltages.

### **2.9 Earth potential rise**

The earth potential rise is the maximum potential rise of an earthing system, with respect to remote earth.

### **2.10 Earthing conductor**

The earthing conductor is a conductor used to connect any metal work required to be earthed to the neutral point of the transformer or such other earthing point as may be determined.

### **2.11 Earthing system**

The earthing system includes the earth grid and all conductors, piping, electrodes, clamps and other metalwork connected to the grid.

### **2.12 Electrified area**

The electrified area is the section of railway provided with 1500 V<sub>dc</sub> overhead wiring, nominally bounded by Bowenfels, Glenlee, Kiama and Newcastle.



### **2.13 Electrode (also known as earth rod)**

The electrode or earth rod is a vertical conducting element specifically designed or adapted for discharging the earth fault current into the ground as required by the earthing system design.

### **2.14 Electrolysis**

Electrolysis refers to the process where corrosion occurs to a buried metal structure when dc current leaves the structure to enter the electrolyte of the surrounding soil.

### **2.15 High voltage**

This is a voltage exceeding 1000  $V_{ac}$  or 1 500 Vdc.

### **2.16 Installation main switchboard**

This is a low voltage switchboard from which the supply to the whole installation can be controlled. An installation is as defined in AS 3000, SAA Wiring Rules. This switchboard contains the consumer terminals and should not be confused with the supply main switchboard, refer to definition 2.36.

### **2.17 Insulated**

Insulated means separated from adjoining conducting material by a nonconducting substance which permanently provides resistance to the passage of current, or to disruptive discharges through or over the surface of the substance at the operating voltage, to obviate danger of shock or injurious leakage of current.

### **2.18 Local Electricity Distributor**

The local electricity distributor is any organisation engaged in the supply of electricity, excluding the Australian Rail Track Corporation.

### **2.19 Low voltage**

Low voltage is a voltage exceeding 50 Vac or 120 Vdc but not exceeding 1000 Vac or 1 500 Vdc.

### **2.20 Metalwork**

Metalwork includes any reinforced or prestressed concrete parts of an installation but shall exclude minor attachments to wood poles and wood pole identification discs.

### **2.21 Near 1500 V track**

Near 1500 V track is that area inside the railway boundary and within

- 20 m of the centre-line of any track with overhead wiring which is electrified at nominal 1500  $V_{dc}$ , or
- 20 m of any 1500  $V_{dc}$  negative equipment or conductors, or
- 20 m of any metal which is spark-gapped to the rail measured horizontally at right angles.

## **2.22 Point of attachment**

The point of attachment is the point at which a local Electricity Distributors service mains are terminated on a ARTC building, pole or structure.

## **2.23 Prospective touch voltage**

The prospective touch voltage is the voltage difference which may appear between any uninsulated metalwork located within 2.4 metres of the ground and any point on the surface of the ground separated by a horizontal distance of one metre, which is considered to be equal to a person's normal reach.

## **2.24 ARTC consumer's terminals**

ARTC consumer's terminals are the point at which the ARTC Distribution system is connected to the consumer's installations.

## **2.25 ARTC service mains**

The ARTC service mains are the conductors between the supply main switchboard, or change-over panel if there is a back-up supply, and the ARTC consumers terminals on the installation main switchboard.

## **2.26 ARTC supply**

The ARTC supply is an electricity supply taken from a Australian Rail Track Corporation owned high voltage or low voltage network.

## **2.27 Rail**

Rail is the traction rail, that is the rail intended for conduction of the traction return current.

## **2.28 Railway corridor**

The railway corridor is any land owned by one of the three railway entities nominated under the Transport Administration Amendment (Rail Management) Act 2000, ie, Australian Rail Track Corporation, State Rail Authority of NSW or Freight Corp.

## **2.29 Remote earth**

Remote earth is a true earth potential of zero volts.

## **2.30 Sectioning Hut**

A sectioning hut is a System Substation, with dc circuit breakers but without rectifiers, that sectionalises the 1500 Vdc overhead wiring for dc protection and voltage regulation.

## **2.31 Service equipment**

Service equipment is the metering and control equipment supplied and installed as specified in either ARTC's or the local Electricity Distributor's service and installation rules.

### **2.32 Service line**

Service lines are the conductors supplied by a local Electricity Distributor to the point of attachment.

### **2.33 Spark gap**

The spark gap is a device used to connect specific types of 1500 V structures (refer to Specification EP12200001 SP - "Bonding of Overhead Wiring Structures to Rail" contained in Volume 1) to rail when the potential difference between the two rises above 750 V.

### **2.34 Step voltage**

The step voltage is the voltage which may appear between any two points on the surface of the ground separated by a horizontal distance of one metre, which is considered to be equal to a person's normal step.

### **2.35 Substation**

This a substation, traction substation, transformer room, switchroom, sectioning hut, pole or pad mounted transformer location, containing high voltage electrical equipment.

### **2.36 Supply main switchboard**

The supply main switchboard is the first low voltage switchboard between the transformer terminals and the low voltage installation. The supply main switchboard is owned by ARTC and is the location to establish the one and only connection between earth and neutral.

### **2.37 Switchboard**

A switchboard is any distribution board or switchboard other than the supply main switchboard or installation main switchboard.

### **2.38 System Substation**

A system substation a traction substation, sectioning hut or a substation location that has a voltage greater than 2 kV and includes a high voltage circuit breaker as an item of equipment. The voltage of greater than 2 kV has been selected to exclude the ARTC 2 kV (nominal) distribution system.

### **2.39 Touch voltage**

Touch voltage is the voltage across the body, under fault conditions, in a position described as for the prospective touch voltage but allowing for the voltage drop caused by a current flowing in the body.

### **2.40 Traction Substation**

A traction substation is a System Substation that supplies 1500 Vdc power for the overhead wiring using high speed dc circuit breakers.

### **2.41 Transfer voltage**

Transfer voltage is the voltage difference between an earthing system and an exposed metal object connected to a remote earth.

### **2.42 Transformer mains**

Transformer mains for a supply from the ARTC high voltage network are the conductors between the transformer secondary terminal and the supply main switchboard, or change-over panel where there is a back-up supply. For a supply from a local Electricity Distributor network the transformer mains are the conductors on either side of the isolating transformer, that is, between the service equipment and the supply main switchboard, or change-over panel where the supply is installed as a back-up supply.

### **2.43 Voltage**

Voltage means nominal potential difference between conductors or the nominal potential difference between a conductor and earth, whichever is applicable.