

Certificate No. NESA-S106

Version No.1.0

Approval date 29 April 2024

Approved by Head of Engineering Standards

This certificate is issued to

Supplier Eaton Industries Pty Ltd

In respect of

Manufacturer Eaton Industries Pty Ltd

10 Kent Road

Mascot NSW 2020

Product description 9SX UPS System

Item identification Eaton UPS 9SX Series

Application Network Wide

Relevant Standards ESS-09-02 Signalling Power Systems

SPS 02 Environmental Conditions

SPS 05 Electrical & Electrical Components (Ratings & Construction Requirements)

ESA-09-05 DC Power Supply Units and Battery Charger Power Supplies for Signalling Equipment.

Conditions of Approval

1. Full type approval has been given for the use of Eaton's 9SX UPS under the assumption that they would be used in locations defined in SPS 02 as type A1 and A2. Thus, they shall be based at a location that is air-conditioned.
2. For use in accordance with the manufacturer's requirements and ARTC standards .
3. Only components from the list may be utilised.

A general condition of approval is that the supplier remains accredited to ISO 9001 specifically for these products and ARTC is advised on a 12 monthly basis that accreditation is current. ARTC reserves the right to conduct its own audit of the manufacture and supply of these components to AS 19011.

Any subsequent change to the design, materials or manufacturing process is not covered by this approval. The manufacturer should notify ARTC of any modification or changes in order to obtain a valid certificate.

Note/Comments



NEW EQUIPMENT AND SYSTEM APPROVAL CERTIFICATE

Issue date

29/04/2024

Expiry date N/A

Issued by

ARTC Manager Signalling Standards