

Certificate No.: **S-01-10-096** 

## **NEW EQUIPMENT & SYSTEM APPROVAL CERTIFICATE**

Approval date: 13 September 2010

Approved by: ARTC Risk & Safety Committee

**Report no.:** TAS 01-0710-WE105

Report date: 30 July 2010

This certificate is issued to:

Supplier:

**Invensys Rail Pty Ltd** 

In respect of:

Manufacturer:

Invensys Rail Pty Ltd 179-185 Normanby Rd South Melbourne Victoria 3205

**Product description:** 

**WESTRACE - COMPUTER BASED INTERLOCKING SYSTEM** 

Item identification:

See approved item list for certificate S-01-10-096

**Application:** 

Signal Interlocking System on ARTC network

**Relevant Standards:** 

SCP 17 Computer-Based Interlocking Requirements

**Conditions of Approval:** 

- 1. For use in accordance with ARTC specification SDS 25 and standard typical circuits only.
- 2. All vital parallel output circuits must be capable of being returned to a safe state by the de-energising of a vital relay (OPCR). The OPCR relay shall be to Network Rail specification BRB 930, 50v DC neutral, plug board pin codes 003 or 004.
- All serial communications links shall be over a closed communication path reserved specifically for signalling purposes.
- Where LED type signal lamp aspects are fed directly from a VLOM then an additional sensor (external to the VLOM) is required to provide vital lamp proving detection except where a suitable dummy load can be provided in parallel with the signal aspect(s). The dummy load shall itself be sufficient to neither initially operate nor hold operated the VLOM lamp proving function.
- 5. Only the latest approved version of the card frames, backplanes and functional modules together with any integrated software and the associated development system software, may be used in new works installations.
- 6. At high traffic density sites on the ARTC network, WESTRACE housings used to implement vital interlocking logic shall be configured in hot standby.
- 7. WESTRACE housings used only as Signalling Object Controllers or for non-vital communications may be standalone (not hot standby) configuration.
- 8. Only components from the list in Attachment A may be utilised.
- 9. All WESTRACE housings at a site (included in the same circuit book) shall use card frames, functional modules and executive software referenced on the same ARTC acceptance certificate.
- 10. The updated WESTRACE Certified Module List showing the latest changes shall be provided.

A general condition of approval is that the supplier remains accredited to ISO 9001 specifically for these products and ARTC is advised on a 12 monthly basis that accreditation is current. ARTC reserves the right to conduct its own audit of the manufacture and supply of these components to AS 19011.

Any subsequent change to the design, materials or manufacturing process is not covered by this approval. The manufacturer should notify ARTC of any modification or changes in order to obtain a valid certificate.

**Note/Comments:** 

This certificate includes updates to the WESTRACE System previously approved under certificate 08-08-10-037 and Type Approval Report TAR 01-0605-026.

**Issue date:** 

16/11/2010

Issued by:

Page: 1 of 3

John Furness, ARTC Manager Standards

## NEW EQUIPMENT & SYSTEM APPROVAL - APPROVED ITEM LIST

Reference no.:

TAS 01-0710-WE105

Date:

13 September 2010

**Product description:** 

**WESTRACE - COMPUTER BASED INTERLOCKING** 

Certificate no.:

S-01-10-096

The following lists the individual items (by catalogue number) are approved for use on ARTC infrastructure under the above referenced New Equipment & System Approval Certificate number, subject to any conditions shown on that Certificate and the Conditions of Use shown against individual items.

Catalogue No.	Item Type	Description	Conditions of Use
		Housings for 1	9" rack mounting.
1690 1067 01	Cardframe	1 shelf housing.	
1690 1068 01	Cardframe	2 shelf housing for 1 x PSU24.	
1690 1068 02	Cardframe	2 shelf housing for 2 x PSU24.	
1690 1069 01	Cardframe	3 shelf housing for 1 x PSU24.	
1690 1069 02	Cardframe	3 shelf housing for 2 x PSU24.	
1690 1069 03	Cardframe	3 shelf housing for 3 x PSU24.	
1690 1070 01	Cardframe	4 shelf housing for 1 x PSU24.	
1690 1070 02	Cardframe	4 shelf housing for 2 x PSU24.	
1690 1070 03	Cardframe	4 shelf housing for 3 x PSU24.	
1690 1070 04	Cardframe	4 shelf housing for 4 x PSU24.	
2650 1126 01	Backplane	VLE System backplane.	
		Interlock	ing Modules
3650 1141 12	VLM6	VLC6, OPC50 and UHBC in one item	To be configured with a Hot Standby for Interlocking Units on High Traffic lines.
1690 1023 01	VROM50	Vital Relay Output	(existing installations) Version Number 4.0 (for new installations) Version Number 4.4
1690 1020 01	VLOMFT110	Vital Lamp Output	Version Number 3.5
1690 1007 01	VPIM50	Vital Parallel Input	Version Number 3.5
3650 1131 01	PSU24	Power Supply	
4650 1057 01	Blanker	n/a	
C	Communications Mo	odules	Communications link must be a closed system to carry vita data.
4663/270	NCDM	Communications Interface	(for existing installations) p/n B47000/137AA Mod state D rev 6
			(for new installations) p/n B47000/137AA Mod state E rev 8
3650 1141 13	WNCM	VLC6 and NCDM in one item.	To be configured with a Hot Standby for Interlocking Units on High Traffic lines.
3650 1129 13	EVTC232	Vital Telemetry	Version Number 2.1

Catalogue No.	Item Type	Description	Conditions of Use
		Filter	Modules
4663/271	NCD PFM	For NCDM card	(for existing installations) p/n B47000/138DA Mod state A rev 4
			(for new installations) B47000/138DA Mod state C rev 8
3650 1123 01	SIO232PFM	For SIO232 card	
3650 1137 04	VROM50PFM	For VROM50 card	
3650 1135 04	VLOM110PFM	For VLOM110 card	Two items are always required to protect all 12 outputs or each VLOM110.
3650 1112 01	VPIM50PFM	For VPIM50 card	
3650 1136 04	OPC50PFM	For OPC50 card	
2650 1140 01	HOPC PFM		
3650 1104 01	PSU24PFM	For PSU24 card	
		Sof	itware
n/a	GCS	Graphical Configuration System	Version 7.0.0 (for Windows XP). and Version 7.1.3 (for Windows XP).
n/a	ICS	Installation Checking	Version 7.0.0 (for Windows XP).  and  Version 7.1.3 (for Windows XP).
n/a	MoviolaW	Maintenance & Diagnostic	Version 3.0.0.4 (for Windows XP).
n/a	PCGE	Graphical Display Editor	Version 3.63 (for Windows XP).
n/a	GCSS	Graphical Configuration Sub System	Version 7.0.0 (for Windows XP). and Version 7.1.3 (for Windows XP).
n/a	GSIM	Graphical Simulator	Version 5.0.0 (for Windows XP).
n/a	ISIM	Interlocking Test Simulator	Version 1.0
		Ancillary	Equipment
			All below for spares use only.
2680 0004 35	VLC6	Vital Logic Controller	p/n B47000/134AA Mod state C rev 5
3650 1102 04	OPC50	Output Power Controller	
4663/268	UHBC	Vital Control Unit Backplane	p/n B47000/135AA Mod state A
3650 1147 01	EXP1	PSU 2 shelf expansion cable.	
3650 1148 01	EXP2	PSU 3 shelf expansion cable.	
3650 1149 01	EXP3	PSU 4 shelf expansion cable.	
3650 1144 01	EC1	Bus expansion cable 1 shelf local.	
3650 1145 01	EC2	Bus expansion cable 2 adjacent shelves.	
3650 1146 01	EC3	Bus expansion cable spans 3 shelves.	
		Not manufact	cured by WRSA
n/a	29F010	70nS Flash EPROM	
n/a	Dataman S4	PROM Programmer	Available from RS Components Pty. Ltd.