

NEW EQUIPMENT AND SYSTEM APPROVAL CERTIFICATE

Certificate No. S 05 1612 AP200

Approval date 16/02/2017
Approved by GM Technical Standards
Report no. TAS 5-1602-AP186
Report date 10/12/2016

This certificate is issued to

Supplier Alpha Power Systems
737 Burwood Road
Hawthorn
Vic 3122

In respect of

Manufacturer Alpha Power Systems
Product description Manual/Automatic Transfer Switch MATS002R
Item identification Refer to Approved Item List.
Application ARTC Network Wide
Relevant Standards SPS 02 Environmental Conditions
SPS 03 Signalling Power Systems
SPS 22 Power Supply Units for Signalling Equipment – General Requirements
ESD-09-01 Signalling Power Systems

Conditions of Approval

1. Alpha Power Systems to inform ARTC of any changes that may affect their acceptance of all requirements stipulated within ESG-00-15 'Quality Controlled Supplier' standard
2. The MATS002R shall only be bolted by the front mounting holes to any 19" racking.
3. Only items in the approved list may be used.
4. There are no field serviceable components within the unit, any failed units shall be replaced.
5. The supplier or manufacturer must advise ARTC of any changes made to the product or system which may alter its identification, performance characteristics, form, fit, function or processes required for correct usage so that this approval can be revised or reviewed.

NEW EQUIPMENT AND SYSTEM APPROVAL CERTIFICATE

Any subsequent change to the design, materials or manufacturing process is not covered by this approval. The manufacturer should notify ARTC of any modification or changes in order to obtain a valid updated certificate.

Note/Comments

NIL.

Issue date 16 February 2017

Expiry date N/A

Issued by

John Furness 
ARTC Manager Standards

NEW EQUIPMENT AND SYSTEM APPROVAL CERTIFICATE

Approved Item List – Manual/Automatic Transfer Switch

Part Number	Description
MATS002R-110	Manual/ Auto Transfer Switch – Rack Mount 110/230 VAC, 65A max @AC1 Alarm Voltage free contacts, 5A max.